

Peabody Engineering

Hamworthy Engineering group



Peabody Engineering
an hwy group



NOx and Efficiency Solutions for Boilers

Energy Solutions Center
Low NOx Workshop
Cambridge / Markham, Ontario
November 13 / 14, 2002



Peabody Engineering
an hwy group

Presentation Outline

- **Peabody Introduction**
- **NOx Trends**
- **Peabody NOx Solutions**
- **Impact on Efficiency**
- **Burner Development Goals**
- **Burner Design Features**
- **Sample Field Results**



Peabody Engineering

- Founded 1920
- Locations:
 - Shelton, CT
 - Norwich, NY
 - Toronto, ON
 - Mexico City (JV)




Offices, Subsidiaries, Joint Ventures and Licensees



Products

Utility/Industrial Burners
Low NOx Burners
Low Excess Air Burners



Products

Low Btu Gas/Coal/Kiln Burners



Air Heaters / Incinerators




Ignition Systems



Flame Scanning Systems



In Line Duct Burners




Fuel Preparation Sets




Products


Package Burners –
Envirojet



Trends in NOx Emissions



Trends in NOx Emissions



Factors Influencing NO_x Emissions

- Heat Input
- Combustion Air Temperature
- Furnace Volume
- Furnace Dimensions
- Burner Spacing
- Fuel Composition
- Fuel Bound Nitrogen
- Other Emission Criteria



NO_x Solutions

- Low NO_x Burners
- System Solutions:
 - Flue Gas Recirculation
 - Water/Steam Injection
- Re-engineering Existing Burner Systems
- Combination of Above
- Solution is Boiler Specific



Low Emissions = Low Efficiency

Low NOx Burners:

- Higher Burner RDL**
- May operate at higher O2 levels**
- Increased fan horsepower**

Flue Gas Recirculation:

- Increased mass flow**
- Increased system pressure losses**
- Increased fan horsepower**
- Boiler heating surface considerations**

Water / Steam Injection:

- Water/Steam not recoverable**
- Lower boiler efficiency**



Efficiency Impact

■ Example:

- For a typical 40,000 PPH Packaged Boiler:**
- Fan Motor BHP:**
 - With 15% FGR: 45**
 - Without FGR: 29**
- ~50% Horsepower Penalty for FGR**



Efficiency Impact

- **What is the cost of:**
 - **10 Fan HP per installation for FGR**
 - **Additional Electrical Costs**
 - **Additional Demand for the power provider (and associated power provider stack emissions)**
 - **1% Boiler efficiency loss per installation**
 - **Additional fuel costs**
 - **Safety issues**
 - **Additional controls to assure flame stability**



Burner Development Goals


- **Applicable to Firetube or Watertube Boilers**
- **Dual Fuel (Natural Gas and/or Light Oil)**
- **Low NOx capability (30 ppm – natural gas)**
- **Minimize System Pressure Losses (RDL, No FGR)**
- **Maximize Motor Efficiency**
- **Minimize Power Consuming Accessories (Air compressors, silencers, fuel pressure requirements)**
- **Compact Design (Easy fit on the boiler front)**




ENVIROjet NOx Control

Low NOx Emissions

- *Primary Combustion Zone*
- *Vitiation Zone*
- *Secondary Combustion Zone*
- *Main Flame*




Envirojet



 Peabody Engineering
an IBM Business Partner

Envirojet



 Peabody Engineering
an IBM Business Partner

Envirojet



 Peabody Engineering
an IBM Business Partner

Envirojet Fan / Motor Design

- **Slip Stream Motor Design**
 - **More Efficient**
 - **Combustion air passes over motor**
 - **No motor cooling fan required**


 Peabody Engineering
an IBM Business Partner

Envirojet Fan / Motor Design

- **Acoustically Lined Motor Housing**
 - Provides Noise Levels <85 @ 3 ft.
 - Less pressure drop than conventional designs
 - More compact



ENVIROjet





Compact Design

- “Monoblock” Design
 - Integral Fan / Windbox Housing
 - Combined Motor Housing / Fan Silencer
 - Fan / Windbox Orientation is Rotatable




ENVIROjet Burner





ENVIROjet Burner



Peabody Engineering
an envirojet company

Minimize Power Consuming Accessories

- **Cascade Mechanical Oil Atomizer**
 - **Eliminates Atomizing Steam**
 - **Eliminate Atomizing Air Compressor (HTHW applications)**



Field Results – Park Place

- **Park Place Resorts / Las Vegas, NV**
 - **25,875 PPH Watertube Boiler**
 - **33 MMBTU/HR Heat Input**
 - **NOx Requirement: 30 ppm (Natural Gas)**
 - **Fuel Fired: Natural Gas**



Park Place



■ **Equipment Performance:**

- **NOx Emissions:** 24 ppm
- **FGR:** 0 %
- **CO Emissions:** <50 ppm
- **Fan Motor HP:** 25
- **Noise Level:** < 83 dBA @ 3'



Field Results – United Hospital

■ **United Hospital / Clarksburg, WV**

- 12,000 PPH Watertube Boiler
- 16.3 MMBTU/HR Heat Input
- NOx Requirement: 30 ppm (Natural Gas)
- Fuels Fired: Natural Gas / No. 2 Oil



United Hospital




Equipment Performance:

- NOx Emissions (NG): 24 ppm
- NOx Emissions (Oil): 55 ppm
- FGR: 0 %
- CO Emissions: <25 ppm
- Fan Motor HP: 10
- Noise Level: < 81 dBA @ 3'



United Hospital



Field Results - Bridgestone

- **Bridgestone Tire / Japan (Retrofit)**
 - 600 HP Firetube Boiler
 - 24.6 MMBTU/HR Heat Input
 - NOx Requirement: 35 ppm (Natural Gas)
 - Fuels Fired: Natural Gas / No. 2 oil
 - Variable Speed Drive Fitted




Bridgestone Tire

- **Equipment Performance:**
 - **NOx Emissions:** 30 ppm (50% Reduction)
 - **FGR:** 0 %
 - **CO Emissions:** <50 ppm
 - **Electrical Consumption:** 35 % reduction



Bridgestone Tire

Motor Power Consumption Comparison (Bridgestone Tire)



NOTES! Information supplied by Independent Source.
Tests carried out and reported by end user.
Power saving at 100% is due to improved performance by Envirojet fan system over conventional fan system with TEFC motor.



Summary

- **Low NOx possible without FGR or water injection**
 - **No Efficiency Penalty:**
 - **Minimal Motor Horsepower**
 - **Maximum Motor Efficiency**
 - **No Wasted Steam / Water**
 - **Maximum Boiler Efficiency**



Low NO_x Burner Retrofit Considerations

- Fan Static Capability
- Furnace Dimensions
- Burner Spacing
- Windbox Dimensions
- Air Flow Distribution
- Waterwall Openings
- Furnace Conditions
- Air / Flue Gas Ductwork Arrangement



MSC LOW NO_x BURNER

- Fuel Staging
- Air Staging
- Precise Flame Fit



MSC Burner Precise Flame Fit



- Custom Design Flame Geometry to Specific Furnace Dimensions/Burner Spacings
- Larger Flame Volume Minimizes Localized High Temperature Zones
- Longer Burnout Minimizes CO Emissions



MSC Burner Fuel / Air Staging



- Creates Fuel/Air Rich and Lean Zones
- Reduces Flame Temperature
- Minimizes Oxygen Availability to Reduce Thermal NO_x



MSC Burner Features



- Fixed Geometry
 - No modulating parts
 - Cannot be “accidentally” adjusted out of compliance
- External Gas Manifold
 - Eliminates potential for internal ring cracking
 - Gas spuds can be removed while firing oil



Case History

- Norfolk Naval Station
 - Background:
 - Package Boiler - 150,000 PPH, 250 PSIG, 700°F Steam
 - Conversion of an Existing Low NO_x Burner Retrofit
 - Existing Burner:
 - Used 20% Forced FGR
 - Could not meet Specified NO_x Requirements
 - Caused excessive boiler vibration
 - Experienced frequent flame instability



Norfolk Naval Station

- Peabody Solution
 - New Precision Flame Shape Low NO_x Burner
 - Eliminated FGR Fan
 - Modified FGR Ducting



Norfolk Naval Station Results

Guarantees

	<u>NO_x</u>	<u>CO</u>
Natural Gas	66 ppm	134 ppm
No. 2 Oil	78 ppm	128 ppm

Note: Original burner designed for 20% Forced FGR

Actual

	<u>NO_x</u>	<u>CO</u>
Natural Gas (10% IFGR)	20 ppm	9 ppm
Natural Gas (No IFGR)	36 ppm	11 ppm
No. 2 Oil (10% IFGR)	39 ppm	17 ppm



Case History: System Solution

- Background:
 - Louisiana Paper Mill
 - 225 K PPH Stoker Fired Boiler
 - Natural Gas Fired
 - Four Burners (Arranged 2 over 2)
 - 425°F Combustion Air
 - Existing NO_x Emissions 0.38 #/MMBTU



Louisiana Paper Mill

- Peabody Solution
 - Installed Four New Low NOX Burners
 - Added Steam Atomized Water Injection



Louisiana Paper Mill

- Results:
 - Reduced NO_x to 0.23 #/MMBTU with New Burners (39% Reduction)
 - Reduced NO_x to .135 #/MMBTU by Adding Water Injection (42% Reduction)
 - Overall NOX Reduction of 64%



Case History:

- 705,000 PPH Field Erected Boiler
 - 963 MMBTU/HR Heat Input
 - Six Burners (3 over3)
 - Natural Gas
 - Ambient Combustion Air
 - Replaced Existing Register Style Burners Originally Furnished with the Boiler



Case History

- Peabody Solution
 - Installed Six New Low NO_x Burners
 - Reused Existing Windbox (w/o Modeling)
 - Reused Existing Waterwall Openings
 - Reused Existing Forced Draft Fan (Original Burner RDL less than 6" WC)




Case Study

- Results:
 - Actual Measured NO_x: 0.063 #/MMBTU
 - Actual Measured CO: 0.034 #/MMBTU
 - Actual Burner RDL: 5.5" WC (@ 10% XS Air)




Case History:

MSC Burner



Case History:

MSC Burner



Re-engineering

- Reuse:
 - FD / ID Fans
 - Windbox
 - Register / Ignitor
 - Waterwall Openings
 - Throat Configuration
- New:
 - Fuel Manifold
 - Fuel Nozzles
 - Swirler



Re-engineering

- Approach NO_x Levels of New Burners
- Minimal Impact to Existing Operation
- Installation By In-House Personnel
- Lowest Installed Cost
- Ideal when SCR is a necessity



Summary

- Low NO_x Solution is Boiler Specific
- Burner Solutions Can Meet Most Low NOX requirements
- Burners / Burner Modifications Can Minimize NO_x Entering Post Combustion Apparatus (SCR), thus Minimizing Size of SCR



Contact Information

- Peabody Engineering Corporation
1000 Bridgeport Avenue
Shelton, CT 06484
Lawrence Berry
National Sales Manager
203-926-1111
lberry@peabodyengineering.com
www.peabodyengineering.com



NOx and Efficiency Solutions for Boilers

**Energy Solutions Center
Low NOx Workshop
Cambridge / Markham, Ontario
November 13 / 14, 2002**

